

Permit Reference Number: NP3738SY

Operator: South East London Combined Heat and Power Ltd

Installation: SELCHP

Form Number: NP3738SY / WAT

Date of Form: 01/09/2005

### Reporting of Water Usage for the year 1<sup>st</sup> January to 31 December 2016

Water Source	Usage (m <sup>3</sup> )	Specific Usage (m <sup>3</sup> /t)
Mains water	187,878.47	0.419
TOTAL WATER USAGE	187,878.47	0.419

Trends in Water Usage			
Year	Parameter		
	Named Water source	Total Water usage	Water use per tonne of waste incinerated
2011	Mains Water	289 690	0.67
2012	Mains Water	266,223	0.58
2013	Mains Water	238,137	0.538
2014	Mains Water	195,480	0.45
2015	Mains Water	212,124.55	0.464

Operator's comments:

Signed: Lewis Smith – Environmental Technician  
(authorised to sign as representative of Operator)

Date: 6<sup>th</sup> of January 2017