

Permit Number : EPR/CP3031SX

Operator : Slough Heat and Power Limited

Facility : Slough Heat and Power Station

Form Number : performance 1

**Reporting of other performance indicators for the period.....** YEAR (2016)

Parameter	Result
Number of periods of abnormal operation	3 Occurences this period
Cumulative hours of abnormal operation for this calendar year	2 HRS
B17 Temperatures falls between 800°C and 850 °C	12 Occurences
B17 Temperatures falls between 800°C and 850 °C	24 hours
Operating hours for each incineration line in start-up and shut-down	209 Hours on 46 Occurences 4.5 Hrs Average per occurrence

Operator's comments :

The abnormal operation occurences were a result of one PAC injection failure and two occurences of CEMS loss due to gas cyclinders pressure loss. A breach was incurred when the boiler ran for 9hours below temperature whilst still charging waste during this period on the 26th November.

Signed .....  
(authorised to sign as representative of Operator)

Date.....16/01/2017.....