

**Permit Number:** EPR/ WP3833FT

**Operator:** MVV Environment Devonport

**Installation:** Devonport EfW CHP

**Form Number:** Performance 1 / 06/04/2016

**Reporting of other performance indicators for the period 01/01/2016 to 31/12/2016.**

Parameter	Units	
WID Abnormal Operation	No of occasions calendar year to date	0
WID Abnormal Operation	Cumulative hours for calendar year to date	0
Quantity of municipal waste received on site	tonnes	169,687
Quantity of commercial and industrial waste received on site	tonnes	87,740
Total waste incinerated	tonnes	246,579.80
Quantity of rejected waste sent for off-site disposal	tonnes	20.34
Quantity of rejected waste sent for off-site treatment	tonnes	11.1
Urea consumption	Kgs/tonne of waste incinerated	2.31
Sodium Bicarbonate consumption	Kgs/tonne of waste incinerated	17.10
Activated Carbon consumption	Kgs/tonne of waste incinerated	0.23
Fuel oil consumption	litres/tonne of waste incinerated	2.16
Quantity of APC residues produced	tonnes / Kg/tonnes of waste incinerated	7,185.57 / 29.14
Quantity of bottom ash produced	tonnes / Kg/tonnes of waste incinerated	62,616 / 254
Water consumption	m <sup>3</sup> /tonne of waste incinerated	0.00023

Operator's comments:

Density of urea assumed to be 1.32 Kg/L

Signed .....

(authorised to sign as representative of MVV Environment Devonport Ltd)

Date **06 January 2017**