

Permit Reference Number: EPR/NP3739PD

Operator: CSWDC Ltd

Installation: Coventry EFW Facility

Form Number: WU1 (dated 04/10/2005)

Reporting of Water Usage for the year 2016


Water Source	Usage (m ³)	Specific Usage (m ³ /t)
Mains water	80341	0.29
Site borehole	377356	1.33
River abstraction	0	N/A
TOTAL WATER USAGE	457697	1.62

Trends in Water Usage			
Year	Parameter		
	Named Water source	Total Water usage	Water per tonne of waste processed
2010	Main, river, borehole	572735	2.38
2011	Main, river, borehole	648636	2.82
2012	Main, river, borehole	565771	2.46
2013	Main, Borehole	537174	2.20
2014	Main, Borehole	511616	1.93
2015	Main, Borehole	542653	1.98

Operator's comments: Borehole brought on line spring 2010.
2016: Water use reduced in all areas

Water treatment service engineers and chemical treatment changed late 2015

Signed



(authorised to sign as representative of Operator)

Date 2nd February 2017